



City of Nashua

Central Purchasing
229 Main Street
Nashua, NH 03060

March 13, 2015

SUBJECT:

**ADDENDUM #1
RFP0378-032615
Nashua Wastewater Treatment Facility
Equipment Replacement Fund (WERF) List Updates**

Information included in this document becomes a part of the original Request for Proposals.

Please sign below to indicate receipt of this additional information and include this page with your submittal.

Addendum #1 is being issued to:

Provide answers to questions received prior to the established deadline of Wednesday, March 11, 2015 at 3:00PM.

By submitting receipt of this Addendum #1 with your submittal, you are acknowledging receipt of this document.

All other aspects of the original document remain the same.

Respectfully,

Mary Sanchez, CPPB

Mary Sanchez, CPPB
Purchasing Agent II
City of Nashua

Addendum #1 received and incorporated into submittal for RFP0378-032615.

(Authorized Signature)

(Date)

RFP0378-032615
Nashua Wastewater Treatment Facility
Equipment Replacement Fund (WERF)
List Updates
Addendum 1

Question 1 – Confirm that the remote pump stations are not included in the scope of work

Answer: The 14 pumps stations will be listed individually on the WERF list. Right now some of the pump stations are combined on the list. Approximate costs will be assigned for pumps and controls at each. The Wastewater Engineer has a list of all pump stations and the pumps/controls at each. This will not involve any site visits to the pump stations. In an upcoming project, all the pump stations will be upgraded so detailed evaluation of the existing pump stations is not necessary. The goal is just list all the pumps stations with some rough costs estimates to replace the pumps and controls.

Question 2 – HVAC systems are defined on the City list by building. Is it required to identify individual components in HVAC systems that may need replacement?

Answer: No, replacement of the HVAC system should be restricted to the main air handler unit or exhaust manifold-motor. It should not include duct work or controls since these components are typically not replaced when the unit is in need of replacement.

Question 3 – Various process component coatings are noted on the WERF list. Do they need to be evaluated for replacement.

Answer: No. The reason being is process coatings were recently completed at the plant for a primary sludge thickener tank, all the aeration tanks and all the secondary clarifiers. It just needs to be determined what life cycle to assign the coating which the Wastewater Engineer can assist with in contacting the coating supplier. We also have recent cost information for the coating costs. During your plant evaluation any other tanks or basins that might need coatings should be noted. Only major tanks or basins are to be included in the WERF list.